

Certificate of Compliance

Certificate: 1602385

Master Contract: 165821

Project: 1602385

Date Issued: October 7, 2004

Issued to: Bernstein AG
Postfach 1140
D-32457 Porta Westfalica
GERMANY

*The products listed below are eligible to bear the CSA Mark shown
with adjacent indicators 'C' and 'US'*



Authorized by: G. Foulem

PRODUCTS

CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT – Miscellaneous Apparatus, Panels, Enclosures.
CLASS 3211 87 - INDUSTRIAL CONTROL EQUIPMENT – Miscellaneous Apparatus, Panels, Enclosures,
CERTIFIED TO US STANDARDS

Enclosures for Wall mounting , series CP and CT with suffixes. Enclosure type 1, 4 Indoor, 4X Indoor, 12 and 13

Notes:

1. Certified for use only where the suitability of the combination is determined by CSA International.
2. The type designation may be followed by numbers and/or letters indicating size

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No.	0	-	General Requirements
“ “ “ “ “	94	-	Special purpose enclosures
UL Standard No. 50		-	Enclosures for Electrical Equipment.

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.



Supplement to Certificate of Compliance

Certificate: 1602385

Master Contract: 165821

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
1602385	October 7, 2004	cCSAus Original certification of CP and CT enclosures.